



# TOWN OF OCEAN CITY

*The White Marlin Capital of the World*

**MAYOR**  
RICHARD W. MEEHAN

**CITY COUNCIL**

LLOYD MARTIN  
*President*

MARY P. KNIGHT  
*Secretary*

DENNIS W. DARE  
ANTHONY J. DELUCA  
JOHN F. GEHRIG, JR.  
MATTHEW M. JAMES  
MARK L. PADDACK

**CITY MANAGER**  
DOUGLAS R. MILLER

**CITY CLERK**  
DIANA L. CHAVIS, CMC

## ADDENDUM #1 CAMBRIA BOARDWALK LUMBER

Date of Addendum: November 16, 2020

### NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and will acknowledge receipt of this Addendum in the space provided in the Bid Documents.

### QUOTE SUBMITTAL DEADLINE, LOCATION, AND LAST DAY FOR QUESTIONS

**The quote submittal time has not been changed.**

### 1.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
1.1	I wanted to see if MCA. ground contact treatment is acceptable on all of the decking and railing. <b>Yes Micronized treatment will be acceptable</b>
1.2	2.2 Materials paragraph 2.2.1 I want to make sure that for the stringer lumber we can quote either 4x6 or 4x8. <b>All stringer lumber is 4x6 as indicated on the bid form.</b>

**END OF ADDENDUM**

[www.oceancitymd.gov](http://www.oceancitymd.gov)

P.O. BOX 158 • OCEAN CITY, MARYLAND • 21843-0158



City Hall – (410) 289-8221 • FAX – (410) 289-8703